



# Certificate of Compliance

**Certificate:** 2221455

**Master Contract:** 230398

**Project:** 2221455

**Date Issued:** 2009/09/21

**Issued to:** Fabelta Aluminum Inc.  
3840 Georges Corbeil  
Terrebonne, QC J6X 4J4  
Canada  
Attention: Martin Lortie

*The products listed below are eligible to bear the CSA Mark shown*



*Damtew Tesfaye, P. Eng.*

**Issued by:** Damtew Tesfaye, P. Eng.

## **PRODUCTS**

**CLASS 8029 02** - BUILDING PRODUCTS AND MATERIALS- Windows

PVC Windows:

ER

Casement 1501-4916 Series 27 to 30\*

Fixed Casement 1502-4916 Series 26 to 29\*

Aluminum Windows:

ER

Casement 4-5/8" 25 to 28\*

Double Slider 26 to 33\*\*

Casement Fixed 4-5/8" 25 to 28\*

Casement 1001-0712 Series 24 to 27\*

Fixed Casement 1002-0712 Series 24 to 27\*

Aluminum/PVC Hybrid Windows:



**Certificate:** 2221455

**Master Contract:** 230398

**Project:** 2221455

**Date Issued:** 2009/09/21

---

	ER
Hybrid 8000 Series Casement	27 to 30*
8100 Series Single Hung	28 to 32*
Casement FIXED 2002-0458 Series	26 to 28*
Single Sliding 2007-0458 Series	28to 31*
Double Sliding 2008-0458 Series	25 to 28*
Double Hung 4-5/8"	25 to 29*

**\*current range of ER values are with double glazing and Inex:TP-D spacer and 90% argon gas fill and Low-E of RLE 75/68 on face 3 for all cases. High ER values in all cases represent option without divider grill and low value in the range achieved with addition of divider grills.**

**\*\* Current range of ER values represent triple glazing with argon fill in the outer gap and air fill in the inner, RLE 75/68 Low-E on face 3. The higher ER represent gap with no divider grill and the low with divider.**

#### **APPLICABLE REQUIREMENTS**

CSA Standard A440.02-2004